



Keith Stewart

Director, Purchasing and Supply Services

<https://mail.google.com/mail/u/0/?tab=om> - inbox

Mullikin Bus Lot Renovation/Addition Construction Services

SOLICITATION NO. DCP22-07

ADDENDUM NO. NINE (09)

<u>ISSUED BY</u> DEPARTMENT OF PURCHASING AND SUPPLY SERVICES CONSTRUCTION PROCUREMENT OFFICE PRINCE GEORGE'S COUNTY PUBLIC SCHOOLS, UPPER MARLBORO, MARYLAND 20772	<u>ADDENDUM DATE</u> September 14, 2022 Number of Addendum Pages – TWO (02)	<u>PROPOSAL SUBMISSION DATE</u> September 22, 2022 2:00 P.M., Eastern Standard Time
	<u>RFP No.</u> DCP22-07	<u>RFP ISSUANCE DATE:</u> March 22, 2022
	<u>PROJECT TITLE:</u> <u>MULLIKIN BUS LOT RENOVATION/ADDITION CONSTRUCTION SERVICES</u>	

TO ALL PROSPECTIVE OFFERORS AND OTHER RECEIPTS OF SOLICITATION DOCUMENTS

This Addendum is hereby made a part of the Contract Document, which will be the basis of the Contract. This Addendum is issued to modify and/or correct the original Contract Documents issued on March 22, 2022. Prospective Offerors are requested to attach this Addendum to your Contract Documents. Receipt of this Addendum must be acknowledged on the Proposal. Failure to do so may subject the proposer to disqualification.

The following RFP Provision is hereby changed as follows:

Insert RFP Questions & Answers

- Listed below are answers to questions received from potential proposers.

	Questions	Responses
1.	On the Bus Wash there is a dark band around the exterior elevations. Is this to be a different color ground face than the rest?	YES, DIFFERENT COLOR GROUND FACE CMU.
2.	Per A1.03 - can the wall highlighted in red be regular gray CMU until it goes above the roof and then switch to ground face?	YES, THAT IS ACCEPTABLE.
3.	What type of cavity insulation is required behind the ground face? Detail 7/A6.04 indicates 2" rigid with an R20 value. We do not know of any 2" insulation that will provide that. The specs seem to allude to polystyrene insulation but 2" polystyrene will only provide an R value of 10.	X
4.	Is there a preferred size, model, and grate finish for the trench drain?	THERE IS NO PREFERENCE OF FINISH OR MANUFACTURER AT THIS TIME EXCEPT SIZE AND MODEL WILL HAVE TO BE COORDINATED WITH BUS WASH EQUIPMENT.
5.	Is there a detail for final connection of the Bus Wash equipment?	THIS QUESTION IS NOT CLEAR – IF THIS HAS TO DO WITH PLUMBING, ALL WATER USED AT BUS WASH BAY WILL BE RECYCLED.
6.	Please provide missing section 007419 MBE Forms and confirm the MBE participation requirements.	MBE 7419 Forms were replaced with MBE 3325 Attachments 1-6 per Addendum No. 2 dated May 23, 2022.

END OF ADDENDUM No. NINE (09)